NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report	LL REPORT RECEIVED		· ·	-	
water resources department, A C STATE OF	<b>OREGON</b> (or print) OCT 29 1981	2s/	7E-:	<u>33 aa</u>	
of well completion.	bove this lineWATER RESOURCES DEPT	No	**************************************		
(1) OWNER: Paul R. Munsell Jr.	(10) LOCATION OF WELL:				
INAME	County Clackamas Driller's well number 8]-]				
Address 620 Sweetbriar Land Troutdale, Oregon 97060	ne 14 ne 14 Section 33 T. 28 R. 7e W.M. Bearing and distance from section or subdivision corner				
(2) TYPE OF WORK (check):	Lot 15 Sandy river acres on east				
New Well Deepening Reconditioning Abandon	Bailey Road	Bailey Road			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.				
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 18 ft.				
Cable 🖸 Jetted 🗍 Domestic 🕱 Industrial 🗍 Municipal 🗍	Static level , 100 ft. below land surface. Date 8-10-81			-10-81	
	Artesian pressure lbs. per square inch. Date				
(5) CASING INSTALLED: Threaded [] Welded []	(12) WELL LOG: Diameter of well below casing				
	Depth drilled 300 ft. Depth of completed well 300 ft.				
"-Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size	and struc	ture of 1	materials;	
PERFORATIONS: Perforated? U.Ves XVNo	and show thickness and nature of each stratu with at least one entry for each change of forma	tion. Repo	ort each	chango in	
Tune of performance and	position of Static Water Level and indicate prin	icipal wat	er-beari	ng strata.	
Size of perforations in. by in.		From	To	SWL	
perforations from	Gray clay and solid basalt	0	20 50	18	
perforations from ft. to ft.	Green basalt	50	80		
perforations from ft. to ft.	Gray clay and basalt	80	300	100	
(7) SCREENS: Well screen installed?  Ves X No					
Manufacturer's Name		┨────┤			
Type					
Diam Slot size Set from ft. to ft. to ft. to ft.					
(8) WELL TESTS: Drawdown is amount water level is lowered below static level				· · · · · · · · · · · · · · · · · · ·	
Was a pump test made?  Yes KNo If yes, by whom?					
Yield: gal./min. with ft. drawdown after hrs.					
				······································	
Bailer test 15 gal/min. with 65 ft. drawdown after ] bre					
	and the second				
perature of water Depth artesian flow encountered	Work started 6-3-81 10 Complete	8 70	0.7		
	19 Complete	· · · · ·		19	
(9) CONSTRUCTION: Well seal-Material used Portland coment	Date well drilling machine moved off of well	8-12-	81	19	
Well seal-Material used Portland Coment Well sealed from land surface to 25	Drilling Machine Operator's Certification: This well was constructed under my	direct	611 m o m	rigion	
Diameter of well bore to bottom of seal $\frac{10}{10}$ in.	Materials used and information reported above are true to my best knowledge and belief				
Diameter of well bore below seal	[Signed] Walking the 9-6-81				
Number of sacks of cement used in well seal Ju	(Drilling Machine Operator) Drilling Machine Operator's License No				
How was cement grout placed? <u>Pressure grouted</u>	Diming Machine Operator's License No.	1.594			
	Water Well Contractor's Certification:			**	
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.				
Was a drive shoe used? 🗌 Yes 🕵 No Plugs Size: location ft.					
Did any strata contain unusable water? <u>Yes</u> No Type of water? <u>depth of</u> strata	Name W.a. Knapp. dba. Zig. Zag. Enterprises. (Person, firm or corporation) (Type or print)				
Type of water? depth of strata	Address Box 268, Rhododandron or 97049				
Was well gravel packed? [] Yes Y No Size of gravel;	[Signed] // Margaret				
Gravel placed from	Contractor's License No. 762 Date 9-6				
(USE ADDITIONAL SH				. 19	
	······································		SD*	45656-119	